## A TIP FOR ENERGY CONSERVATION

Recently we had an opportunity to be in a paper mill on a proposal for a new Captive power plant. The customer had explained his difficulties that due to recession the project is shelved. The subject of discussions had drifted to the excess power consumption in their boiler house. The customer said that their power consumption is more than that of a similar capacity plant elsewhere. The boiler is a Husk fired fluidized bed combustion boiler with underbed firing system supplied by a south based boiler manufacturer. The boiler specifications are 12 TPH, 10.5 Kg/Cm², saturated steam.

When asked about the steam demand of the plant, the plant manager informed that the a maximum of 5 TPH would be the steam demand. We reacted immediately that the oversized equipment would draw more power as the dampers kill the energy. The customer discussed about the means of reducing the power consumption.

We studied the draft equipment layout. We had proposed to install a smaller FD fan and Primary air fan. The customer did not want to take a risk. The customer desired that any modification shall be done without disturbing the existing draft equipment. Then it was decided to add the right size FD and PA fans. The locations of the fans were finalized in such a way that with minimum down time, the new Fans could be connected to the existing system. The ID fan was left as it is. We suggested that a variable frequency drive is installed for ID fan. Incidentally by the reduction of speed of the impeller, the life of the fan impeller would also increase. The power consumption figures were calculated to be half of the present load. The payback was very attractive. The customer went ahead with the proposal for new draft equipment and variable speed drive.

The following are the facts and figures of energy saved:

BEFORE MODIFICATIO	N	AFTER MODIFICATION							
Total Installed Power (KW)	73.0 KW	Total Installed Power (KW)	42.2 KW						
Total power consumed /Day	1,752 KW	Total Power consumed /Day	1,012.8 KW						
Total power consumed /Year	5,60,640 KW	Total power consumed /Year	3,24,096 KW						
Total Power Cost per Year	5,60,640 X 4.00	Total Power Cost per Year	3,24,096 X 4.00						
	RS. 22,42.560.00		RS. 12,96,384.00						
Net Saving per Year	RS. 22,42,560.00	0 - RS. 12,96,384.00 = RS. 9,46,176.00							
NET SAVING PER MONTH         RS. 9,46,176.00 DIVIDED BY 12 MONTH         = RS           MONTH         78,848.00									

## **MODIFICATION COST**

FD Fan with Motor	:	Rs. 1,65,500.00
PA Fan with Motor	:	Rs. 90,000.00
AC Variable Speed Drive for ID	:	Rs. 2,30,000.00
Fan		
Ducting for FD and PA Fan	:	Rs. 65,000.00
Erection cost for above Works	:	Rs. 15,000.00
Total	:	Rs. 5,65,500.00
18% Interest for Investment	:	Rs. 1,01,790.00
Total Expenditure	:	Rs. 6,67,290.00
Therefore Feed Back Period	:	Rs. 6,67,290.00 / Rs. 78,848.00 = 8.46 Months

If you are interested to do similar modification in your boiler to save energy, please do not hesitate to write to us for permanent solution & suggestions. Fill in the enclosed data sheet if you need our assistance.

BOILER ANNEXU	ENERGY S	AVIN	IG DA	ATA S	HEI	ET							
Company Name and Address						Contact Persons					Ph	one N	os.
Make of E	oiler					Design stea	ım T	emp.				Deg	С
Design Capacity	Boiler			Kg/H	r	Present Stea	am (	Capaci	ity			Kg/I	- Ir
Design Pressure	boiler			Kg/C	m <sup>2</sup>	Present Stea			Kg/C	Cm <sup>2</sup>			
No of com	partments de	esign				No of Com	part	ments	in op	eratio	n		
Fuel Fired													
Fuel Firing							-						
Cost of fu													
Cost of po													
Type of f													
	RAMETERS												
ID FAN		FD 1	FD FAN			PA FAN				SA FAN			
Flow		Flov	V			Flow	Flow			Flow			
Pressure		Pres	sure			Pressure				Pres	sure		
Temp.		Temp.				Temp.				Temp.			
Motor		Motor				Motor				Motor			
Speed		Speed				Speed				Spee			
Orientatio		Orientatio				Orientation				Orie	entatio		
n		n					<i>J</i> 11			n			
Drive		Driv				Drive				Driv			
Arrgt.		Arrg	ţt.			Arrgt.  BOILER		CCES	SODI	Arrg		IN T	THE
TEMPER	ATURE PR	OFIL	Æ			BOX)	A	CCES	SUK	IES (	(IICK	111 1	.1112
Furnace T	emperature					Steam Dr	um			Ban	k Tubes	}	
Shell Outl						Mud Drui	m			Air I	Heater		
Air He Temp.	ater inlet					Shell				MD	С		
Air Heater Outlet Temp.					Bed Coils			Economiser		•			
MDC outlet Temp.				Water wall			Under Feeding Syste		Bed stem				
				Over bed Feeding System									
PRESEN'	r motor i	POWI	ER C	ONSU	MP'								
	Installed	Consumed					Install						
ID Fan	KW/HP		KW/	HP		SA Fan	+	KW/I	112		KW/F	וץ	
ID Fall						SA Faii							

FD Fan	Feed Pump	
PA Fan		

Enclose a copy of General Arrangement drawing of the boiler.

**Company** 

Name and

## SECOND HAND BOILER DATA SHEET →ANNEXURE - II

As part of our business, we are dealing second hand boilers also. At present, we need a boiler capacity 6 TPH, 10.54 kg/cm<sup>2</sup> pressure of any fuel firing system. If you have any boilers to sale, please furnish the details of the boiler and send this date sheet to us to do interact regarding this

Contact

Persons

Phone Nos.

Address														
Make of B	Boiler						Design steam Temp.			p.		•	Deg C	
Design Capacity	В	Boiler		Kg/I	Hr	Present Steam Capa			acity			Kg/Hr		
Design Pressure	t	oiler			Kg/0	Cm <sup>2</sup>	Present Steam Pressure					Kg/Cm <sup>2</sup>		
No of com	partm	ents d	esign				No of Con	npart	men	its in ope	eratio	n		
Fuel Fired														
Type of fu	rnace													
<b>HEATING</b>	G SUI	RFAC	E ARI	EΑ										
Total area	]	Economiser E		В	Bank		Super hea	Super heater		Water wa		Air heater		
PRESENT MOTOR POWER CONSUMPTION														
	Insta				onsumed					stalled		Consumed		
ID E	KW/HP KW/			V/HP		CAE			KW/HP		KW/HP			
ID Fan							SA Fan	Feed Pump						
FD Fan PA Fan						Feed Pu	mp							
ITEM FOR SALE (TICK IN THE					IE D	VEC	<u> </u>							_
		LE (I				JAES	_	1 , 1	1		D.	014	,	_
PHS Syste			_	ysten				Main Oil tank			Day Oil tan			
Basic boile	er		Chin	nney			Control panel  Dust Colle		oct	Supp. Structure		ture		
Ducting			Bunl	ker			system		J011C	Ref		efractory		
Feed water		nk Fans & M			otors		Ash feed	Ash feeder			Pumps			
Fuel feede	r		Valv	es	Water level g			vel g	,8-		LLG			
All gauges	}	Cables				Burners				Blowdown system				
PURPOSE OF SELLING														
Expected scope	Price	e for	the											
Enclosures	3			Latest IBR Certificate			Inspection Boiler GA Dra			Drawin	ıg			
				1						1			l .	_